

C.No.738 /FSD/FPW/NOC/2025/ 744
FIRE SAFETY CERTIFICATE

EoDB Application No. : 204857

Dated: 27.10.2025

Certified that the A-Block and B-Block at Madukarai Raod, Madagadipet, Puducherry comprised of four storeyed school building (A-Block) and three storeyed building (B-Block) owned / occupied by M/s. SMV School have complied with the Fire Prevention and Fire Safety requirement in accordance with the Codes & Standards and inspected & examined by the officers of the Fire Service Department in the presence of Dr. R. Anita, Principal and that the building /Premises is fit for occupancy up to classes LKG to X for the academic year 2025-2026 from the issue of this certificate in accordance with Codes & Standards and subject to compliance of specific conditions as appended:-

1. To obtain occupancy certificate for the building from the PPA at the earliest.
2. To comply fully with the National Building Code of India, 2016 (Part 4 – Fire and Life Safety) and Standards for the present occupancy of the building at the earliest.
3. The Fixed Fire Fighting Installations provided in the building are to be under proper Care & Maintenance as per the Codes & Standards and recorded in registers by employing (24X7) well trained Fire Fighting Crew/Guards.
4. Emergency / Quick Response Team (ERT/QRT) with the above crew along with other Staffs shall be constituted for responding immediately during emergencies for safe & speedy evacuation of the occupants and loss mitigation.
5. The occupant and fire load of the building shall be maintained properly.
6. The Electrical equipment/appliances are to be maintained as per Codes and Standards for the building.
7. To have a total Evacuation Plan / SOP for fire and other emergencies, scheduled Annual time Table / Calendar for Fire Safety Training to the staffs, Table Top Exercise, Mock drill and conduct the same under the supervision of the Fire Service Department.
8. The approved class of occupancy of the building shall not be altered.
9. The Setbacks on all sides, Corridors, Passages, Staircases, Entries and Exits shall always be free of any obstruction for easy movement during any emergency.
10. Any structural addition/alteration in the building shall be made with the prior approval of the Competent Authority and Fire Service Department

Issued on 27.10.2025 at Puducherry.




 (K. ILANGO)
 DIVISIONAL FIRE OFFICER
 PUDUCHERRY

To

M/s. SMV School,
 Madukarai Road, Madagadipet,
 Puducherry.

